

eco-**INSTITUT**, Schanzenstr. 6-20, Carlswerk 1.19, D-51063 Köln

Hilti Entwicklungsgesellschaft mbH
Mrs. Sarah Kretschmer
Hiltistrasse 6
86916 Kaufering

Dear Mrs. Kretschmer,

based on the test report **59360-A001 -L** dated **09/09/2024** the product **CFS-C EL**, commissioned by **Hilti Entwicklungsgesellschaft mbH** fulfills the requirements:

- AgBB scheme: Ausschuss für die gesundheitliche Bewertung von Bauprodukten (Status 2021)

	3 days	28 days
TVOC	< 10 mg/m ³	< 1 mg/m ³
Carcinogenic Substances	< 0,01 mg/m ³	< 0,001 mg/m ³
TSVOC	-	< 0,1 mg/m ³
VOC without NIK	-	< 0,1 mg/m ³
R-Value	-	< 1

Cologne, 09/09/2024



Marc-Anton Dobaj, M.Sc. Crystalline Materials
(Project management)